



CORPORATION STOP SERVICE CONNECTION

NOT TO SCALE

IPS = IRON PIPE SIZE

FIP = FEMALE IRON PIPE THREAD

MIP = MALE IRON PIPE THREAD

NOTES:

1. CORPORATION STOP SERVICE CONNECTIONS SHALL ONLY BE USED FOR SINGLE SERVICES UP TO 2" METER SETTERS AND DOUBLE SERVICES UP TO 1" METER SETTERS. FOR TRIPLE AND QUADRUPLE MANIFOLDS, REFER TO STD. DETAIL 701B GATE VALVE SERVICE CONNECTIONS.
2. SERVICE CONNECTION PIPE SIZE SHALL BE 2" DIAMETER UNLESS OTHERWISE SHOWN ON THE CONSTRUCTION DRAWING.
3. ATTACH 12 GAUGE TRACER WIRE TO WATER MAIN TO MAKE ELECTRICALLY CONTINUOUS.
4. SERVICE PIPE SHALL BE BURIED IN PEA GRAVEL.
5. DIRECT TAPPING OF WATER MAIN IS NOT ALLOWED.

APPROVED: WILLIAM J. CAMPBELL

REV. DATE: JULY 01, 2007

WATER/WASTEWATER DIVISION



STANDARD DETAILS

CORPORATION STOP SERVICE CONNECTIONS

FILE SD701A.DGN DRAWING NO. **701A**